

WEEKLY TESTING RECORD SHEET - POOL



Week Commencing Site Name Pool Name

Day	Time	Operator Initials	Manual Readings								Automatic Controller Readings			Visual Inspection		Operational			
			Temp	Chlorine			pH	Total Alkalinity	Total Hardness	Cyanuric Acid (Outdoor Only)	TDS (Total Dissolved Solids)	Phosphate	ORP	Free Chlorine	pH	Bather Load	Water Clarity (Clear or Cloudy)	Backwash Filter (Y/N)	Actions & Comments
				Free	Total	Combine													
0°	ppm	ppm	ppm		ppm	ppm	ppm	ppm	ppb		ppm		No.						
	Frequency @4 hours*		4 hours Guide**	4 hours 1.0-4.0	4 hours Free CL+1	4 hours <1.0	4 hours 7.2-7.6	Daily 80-120	Daily <400	Weekly 20-50	Daily 3500-5000^	Daily <500							
MONDAY	Open																		
	#2																		
	#3																		
	#4																		
	#5																		
	Close																		
TUESDAY	Open																		
	#2																		
	#3																		
	#4																		
	#5																		
	Close																		
WEDNESDAY	Open																		
	#2																		
	#3																		
	#4																		
	#5																		
	Close																		

IMPORTANT:
 * Or as required by State's Health Regulations or Guidelines.
 ** Operators guide for outdoor pools only (dark blue section). For State Manual Water Quality Standards refer to HealtySwim Table for guidance and your relevant State's Health Regulations or Guidelines.
 ^ Estimate only. Must refer to manufacturers operating manual for appropriate TDS range.

For State Microbiological Monitoring Water Standards refer to HealthySwim Table for guidance and your relevant State's Health Regulations or Guidelines.
 Logbooks should be kept for at least 12 months after the last date of entry, to be made available on demand to an authorised officer of the State's Health Act.
 The records should then be archived for a further six years.
 Disclaimer. Brauer Swim does not make any representations or give any warranties about its accuracy, reliability, completeness or suitability of this information for any particular purpose.

SUPPORT



WEBSITE



WEEKLY TESTING RECORD SHEET - POOL (CONT'D)

Day	Time	Operator Initials	Manual Readings								Automatic Controller Readings			Visual Inspection		Operational			
			Temp	Chlorine			pH	Total Alkalinity	Total Hardness	Cyanuric Acid (Outdoor Only)	TDS (Total Dissolved Solids)	Phosphate	ORP	Free Chlorine	pH	Bather Load	Water Clarity (Clear or Cloudy)	Backwash Filter (Y/N)	Actions & Comments
				Free/Total Bromine	Total	Combine													
0°	ppm	ppm	ppm		ppm	ppm	ppm	ppm	ppm	ppb		ppm		No.					
	Frequency @4 hours*		4 hours Guide**	4 hours 1.0-4.0	4 hours Free CL+1	4 hours <1.0	4 hours 7.2-7.6	Daily 80-120	Daily <400	Weekly 20-50	Daily 3500-5000*	Daily <500							
THURSDAY	Open																		
	#2																		
	#3																		
	#4																		
	#5																		
	Close																		
FRIDAY	Open																		
	#2																		
	#3																		
	#4																		
	#5																		
	Close																		
SATURDAY	Open																		
	#2																		
	#3																		
	#4																		
	#5																		
	Close																		
SUNDAY	Open																		
	#2																		
	#3																		
	#4																		
	#5																		
	Close																		